

SECTION 5

5.14 FLOW MEASUREMENT:

The Board may require pitot installations for future flow measurement at the time the pipe is being installed. If so, a corporation stop shall be installed in order to be converted to a pitot installation at a later date as shown on Sheet 79 of the Standard Drawings.